

To,

The Principal,
M.M. Internation School,
Sadopur, Ambala City.

No.

669

Dated: -

15/2/2021

Subject: - Request for renewal of Safety Certificate of MM International School, Sadopur – Ambala.


Reference: Your office letter dated 03.02.2021.

The School building of **MM International School, Sadopur – Ambala** has been inspected by the Sub Divisional Engineer, Provincial Sub Division No.7 alongwith JE concerned and who have reported that building is structrually safe for running School. The School building Safety Certificate is hereby given upto the period 11.03.2021 to 10.03.2022 with the following conditions:

1. Building of this college will be repaired every year.
2. Water should not be allowed to stagnate around and on the roof of the building.
3. If building is found cracked from anywhere, the same should be got vacated immediately and same should be got repaired immediately.
4. Instituion will be responsible for safety of building from every angle and firefighting equipment should be in functional condition.
5. If the building of this school is to be extended, the same should be first approved from architect.
6. Proof Checked structural drawings should be submitted to this office for record within 01 month after issuing the NOC.
7. Institute shall also ensure safety precautions from false ceiling and vitrified tiles used in dado.
8. NOC may be considered as cancelled by this office if the school violates any of the above points.

This is for your information.

DA/ Nil.



Executive Engineer,
Provincial Division No.1,
PWD (B&R), Ambala Cantt.

Endst.No.

Dated:

Copy of the above is forwarded to the Sub Divisional Engineer, Provincial Sub Division No.7, PWD B&R, Ambala Cantt for information w.r.t. his office Memo.No.470 dated 12.02.2021.

DA/ Nil.


Executive Engineer,
Provincial Division No.1,
PWD (B&R), Ambala Cantt.